

DESIGN REVIEW BOARD

Latah Glen PUD

1 - Recommendation Meeting

December 9, 2020



From :
Design Review Board
 Kathy Lang, Chair
 c/o Dean Gunderson, DRB Secretary
 Neighborhood & Planning Services
 808 W. Spokane Falls Blvd.
 Spokane, WA 99201

To :
Brian T. McGinn, Hearings Examiner
 Louis Meuler, Interim Planning Director
 Tami Palmquist, Principal Planner

CC :
 William Nascimento
 Laguna Canyon Group, LLC
 William Sinclair,
 Storhaug Engineering

Based on review of the materials submitted by the Applicant and discussion during the December 9, 2020 Recommendation Meeting the Design Review Board recommends the approval of the project subject to the following conditions:

- 1. The Board appreciates the Applicant's objective to imbue regional architectural influences on the manufactured residential home designs. The Applicant's community Design Guidelines shall include architectural elements, materials, textures, and colors consistent with the Regional Northwest theme as presented.**

***Please see the following Comprehensive Plan Goals and Policies:** LU 6.9 Facility Compatibility with Neighborhood, and DP 2.6 Building and Site Design.*

***Please see the following Planned Unit Development Code Requirements:** SMC 120 Significant Features, SMC 17G.070.135 Compatible with Surrounding Areas, and SMC 17G.070.140.B.4 & 5 Community Environment*

- 2. The Board strongly encourages the Applicant to utilize black or brown chain-link fencing in all areas where chain-link is proposed, and ornamental fencing in areas highly visible to the public along Inland Empire Way, South Marshall Road, and as visible from Fish Lake Trail.**

***Please see the following Comprehensive Plan Goals and Policies:** LU 2.1 Public Realm Features, LU 5.1 Built and Natural Environment, LU 5.2 Environmental Quality Enhancement, DP 2.5 Character of the Public Realm, DP 2.15 Urban Trees and Landscape Areas, NE 5.5 Vegetation, and N 2.1 Neighborhood Quality of Life.*

***Please see the following Planned Unit Development Code Requirements:** SMC 17G.070.010.5 Open Space, SMC 17G.070.130 Landscaping, and SMC 17G.070.140 Community Environment.*

***Please see the following Development Standards for Mobile Home Parks:** SMC 17C.345.120.D Open Space.*

3. The Applicant is encouraged to utilize additional innovative solutions to manage stormwater, including Low Impact Development best management practices such as pervious pavements.

Please see the following Comprehensive Plan Goals and Policies: LU 5.1 Built and Natural Environment, LU 5.2 Environmental Quality Enhancement, and DP 2.6 Building and Site Design.

Please see the following Planned Unit Development Code Requirements: SMC 17G.070.010.2 Efficiency, SMC 17G.070.010.7 Resource Preservation, SMC 17G.070.125 Site Preparation, and SMC 17G.070.140 Community Environment.

4. The Applicant is strongly encouraged to develop a shared use path connecting the westernmost pedestrian gate to the Fish Lake Trail.

Please see the following Comprehensive Plan Goals and Policies: LU 2.1 Public Realm Features, LU 5.1 Built and Natural Environment, DP 2.5 Character of the Public Realm, NE 13.1 Walkway and Bicycle Path System, NE 13.2 Walkway and Bicycle Path Design, NE 13.3 Year-Round Use, N 2.1 Neighborhood Quality of Life, and N 4.6 Pedestrian and Bicycle Connections,

Please see the following Planned Unit Development Code Requirements: SMC 17G.070.010.2 Efficiency, SMC 17G.070.010.5 Open Space, SMC 17G.070.120 Significant Features, SMC 17G.070.135 Compatibility with Surrounding Areas, and SMC 17G.070.145.B.1 Circulation

Please see the following Development Standards for Mobile Home Parks: SMC 17C.345.120.D Open Space, and SMC 17C.345.120.J Pedestrian Access.


5. The Applicant shall implement Type L1 screening along the entirety of the west edge of the access drive.

Please see the following Comprehensive Plan Goals and Policies: LU 2.1 Public Realm Features, LU 5.1 Built and Natural Environment, LU 5.2 Environmental Quality Enhancement, DP 2.5 Character of the Public Realm, DP 2.15 Urban Trees and Landscape Areas, NE 5.5 Vegetation, and N 2.1 Neighborhood Quality of Life.

Please see the following Planned Unit Development Code Requirements: SMC 17G.070.010.5 Open Space, SMC 17G.070.130 Landscaping, and SMC 17G.070.140 Community Environment.

Please see the following Development Standards for Mobile Home Parks: SMC 17C.345.120.D Open Space.

These final recommendations were approved via a unanimous vote of 8/0.



Kathy Lang, Chair, Design Review Board

Note: Supplementary information, audio tape and meeting summary are on file with City of Spokane Design Review Board.