



FIRE DEPARTMENT

44 W. Riverside Ave, Spokane, WA 99201
(509) 625-7000, (509) 625-7006 (fax)

Fire Prevention Bureau Test and Maintenance Report – Private Fire Hydrant

Inspection Date: _____

Business/Property Information:

Facility/PUD/Etc.: _____

Address: _____

Contact Person: _____ Phone No.: _____

Hydrant # _____ Location: _____

Hydrant Type: _____ No. of hydrants at this location: _____

<u>Test Type</u>	
Annual Dry	[]
Annual Wet	[]
5-Year Fire Flow	[]

Report of private fire hydrant service condition:

Condition Checked	Status (Pass/Fail)	Corrective Action
Access to hydrant maintained		
Paint and Identification Number		
Hydrant barrel found dry		
Hydrant found free of leaks (visual and sound)		
Port threads		
Caps and chain		
Bonnet and barrel		
Port threads greased		
Operating nut		
Hydrant barrel left dry		
Hydrant operation		

Annual Wet - COMPLETE ALL BLANKS – Incomplete forms will be returned.

Number of turns to full open: _____

No. of ports flowed: _____ Static Pressure: _____/_____ Residual Pressure: _____/_____
(Provide data for each port)

Pitot Reading PSI: _____/_____ GPM: _____/_____

Five Year Fire Flow Test (5-year interval): (Use 2 1/2" outlet for testing)

Flow available @ 20psi: _____/_____

Comments: _____

NOTICE TO OWNER: For items noted as failed or needing attention on this report, you are responsible for correcting these items and resubmitting an inspection report when the work is completed and passes inspection.

Owner/Owner's Representative Signature: _____

Registered Testing Firm: _____ Phone: _____

Registered Tester's Signature: _____ Print Name: _____

SFD Registration # _____