

Spokane
FIRE DEPARTMENT
Fire Prevention Bureau

44 W. Riverside Ave., Spokane, WA 99201-0189
Telephone (509) 625-7000 Fax (509) 625-7006

STANDPIPE SYSTEM INSPECTION REPORT

[] 5-year inspection

ALL INSPECTION AND TESTING MUST BE PERFORMED IN ACCORDANCE WITH NFPA 25

Name of Facility _____
Building Name or No. _____ Type of Occupancy _____
Address _____ City _____ ZIP _____
Telephone _____ Dir./Adm. _____ Conferred with _____
Inspected by _____ Title _____ Date _____
Washington State Fire Sprinkler System Contractor License No. _____

Type of standpipe riser(s) being tested:

[] Wet standpipe [] Dry standpipe

AN INDIVIDUAL INSPECTION/TEST FORM AND FILING FEE ARE REQUIRED FOR EACH SYSTEM TESTED.

A FIRE STANDPIPE SYSTEM IS DEFINED AS INTEGRATED COMPONENTS SUCH AS PIPING, VALVES, AND OTHER RELATED EQUIPMENT THAT CAN BE OPERATED INDEPENDENTLY, SERVICES ALL OR A PORTION OF A BUILDING, AND STEMS FROM A SINGLE FIRE DEPARTMENT CONNECTION.

NOTE TO OWNER / OCCUPANT:

All fire standpipe systems are presumed and required to be fully operational and maintained at all times. Fire standpipe system deficiencies and malfunctions are the responsibility of the building/property owner and shall be repaired immediately.

A. **OWNER'S SECTION** (answers may be obtained from the owner or occupant)

1. Explain any occupancy hazard changes since the previous inspection. _____

2. Describe fire protection modifications since the previous inspection. _____

3. Describe any fires since previous inspection. _____

4. Is the building currently occupied? YES ____ NO ____

B. **INSPECTOR'S SECTION** (all responses reference current inspection)

1. STANDPIPE - GENERAL INFORMATION:

YES NO NA

- a. Are the standpipe risers in this building interconnected? _____
- b. Are all standpipe risers in service? _____
- c. Was the standpipe piping *internally* checked for obstruction, corrosion, or foreign material? _____
- d. In areas protected by wet standpipe risers, is the building properly heated in those areas? _____
- e. Are all valves and piping adequately protected from freezing where applicable? _____
- f. Is this building protected by more than one standpipe riser? YES NO HOW MANY? _____
- g. Is this system supplemented by a fire pump ? YES NO

2. CONTROL VALVES

YES NO NA

- a. Are all standpipe system control valves and all other valves in the appropriate open or closed position? _____
- b. Are all control valves in the open position and locked, or equipped with a tamper switch? _____
- c. Control Valve Maintenance Table

CONTROL VALVES	NO.	TYPE	SECURED	CLOSED	SIGNS	CONDITION
City connection control valve						
Tank control valves						
Pump control valves						
Sectional control valves						
System control valves						
Other control valves						

3. TANKS, VALVES, PUMPS, FIRE DEPARTMENT CONNECTIONS

- a. Was the fire department connection check valve cleaned and back flushed from check valve to FDC? _____
- b. Are fire department connections in satisfactory condition, couplings free, caps in place, and check valves tight? _____
- c. Are fire pumps, gravity tanks, reservoirs, and pressure tanks in good condition and properly maintained? _____
- d. Are the fire department connections accessible and visible? _____
- e. Was the backflow preventer properly flushed, tested, and maintained? _____

INDIVIDUAL STANDPIPE RISER REPORTING

For each standpipe *system*, an individual riser reporting form for each *standpipe riser* is required to be attached to the system report. Multiple *individual risers* found within one *system* might include, as similar to the example for sprinkler systems, two Class III wet standpipe risers and one Class II wet riser.

STANDPIPE IDENTIFICATION – Use a # or description unique to this individual riser

- | | YES | NO | NA |
|--|-----|-----|-----|
| 1. WET STANDPIPE RISER | | | |
| a. How many wet standpipe risers are in this building? _____ | | | |
| b. What was residual PSI at the top of riser with 35 GPM flowing? _____ | | | |
| c. How many hose stations on this riser? _____ | | | |
| d. What are the fire hose sizes? (Class II and Class III risers) _____ | | | |
| e. Is hose proper type and in good condition? | ___ | ___ | ___ |
| f. Were hoses re-racked/re-rolled so folds do not occur in the same position?..... | ___ | ___ | ___ |
| g. Are all the fire hoses, nozzles, valves, and gaskets in good working condition? | ___ | ___ | ___ |
| h. Do all hose valves and hoses have National Standard threads? | ___ | ___ | ___ |
| i. Are all hangers and braces securely fastened? | ___ | ___ | ___ |
| j. Is this riser fitted with any Pressure Reducing/Pressure Restricting devices? | ___ | ___ | ___ |
| 2. DRY STANDPIPE RISER | | | |
| a. How many dry standpipe risers are on this building? _____ | | | |
| b. What is the size of the dry standpipe riser being tested ? _____ | | | |
| c. Were all outlet valves on the dry standpipe riser opened and closed to determine that they function properly? | ___ | ___ | ___ |
| d. Are all hangers and braces securely fastened to building? | ___ | ___ | ___ |
| e. Was the dry standpipe riser hydrostatically tested for at least 2 hours @ 200 psi ?..... | ___ | ___ | ___ |
| Results of test: _____ passed _____ failed (Required every 5 yrs) | | | |
| f. Was water flowed through the standpipe riser to the roof? | ___ | ___ | ___ |
| g. Were all standpipes drained, caps replaced, and restored to working condition at end of test? | ___ | ___ | ___ |
| h. Are hose threads and valves in good working order? | ___ | ___ | ___ |
| 3. COMBINATION SYSTEMS (Sprinkler and Standpipe with a common riser) | | | |

USE THE FIRE SPRINKLER INSPECTION /TEST FORM

INSPECTOR'S COMMENTS AND INSPECTION CERTIFICATION

- 1. Explain any "NO" answers and comments. _____

- 2. Adjustments or corrections made during this inspection. _____

- 3. Although these comments are not the result of an engineering review, the following desirable improvements are recommended:

This is to certify that this fire standpipe system has been inspected in accordance with the standards adopted by the Washington State Fire Marshal, Spokane Fire Department, and NFPA Standards 13, 13A, and 25.

Name of inspecting firm _____
Fire Sprinkler Contractor License. # _____ Expiration date _____
Mailing address _____

IT IS MANDATORY THAT THIS SECTION BE COMPLETED

All fire standpipe systems are presumed and required to be fully operational and maintained at all times. Fire standpipe system deficiencies and malfunctions are the responsibility of the building/property owner and shall be repaired immediately.

WERE ANY/ALL DEFICIENCIES CORRECTED? YES NO EXPLAIN: _____

HAS THIS SYSTEM PASSED IN ACCORDANCE WITH STANDARDS ADOPTED BY THE WASHINGTON STATE FIRE MARSHAL, SPOKANE FIRE DEPARTMENT, AND N.F.P.A. STANDARDS 13, 13a, AND 25?

YES NO IF "NO," EXPLAIN ABOVE.

Name _____ Title _____ Date _____
(signature of servicer inspecting/testing system)

Name (print) _____ SFD registration # _____

Name _____ Title _____ Date _____
(signature of facility owner or representative)

Name (print) _____

