

Next Level of Treatment Discussion


Riverside Park Water Reclamation Facility

December 2013



How the City manages runoff

- Separate Storm Sewers
 - Combined Storm & Sanitary Sewers
 - Evaporation
 - Infiltration
-
- Impacts to the plant from CSO and incomplete separation



Integrating work at the Plant

- ▶ Initially, Integrated Plan was to include stormwater and CSO work.
- ▶ Changed thinking:
 - Interconnectivity between stormwater, CSOs, interceptor capacity, and the plant capacity.
 - Influence of stormwater on the size of the plant:
 - Process avg 34 M Gallons of wastewater/day.
 - But headworks sized to handle a flow rate of 125 million gallons/day.
- ▶ Recognized an opportunity to expand our right-sizing program to the plant.



Next Level of Treatment

- ▶ City required to add additional treatment level at the wastewater plant:
 - TMDL for dissolved oxygen/phosphorus
 - Permit deadline for completion is March 2018
 - Completing a study to determine the best approach to achieve regulatory and financial goals.
 - Working with Ecology now to receive approval for our approach. Report to Ecology due Jan. 7, 2014.
 - Construction likely to begin in 2016.

Treatment at the Plant

- ▶ **Pretreatment:** Removal of rocks, grit and larger debris.
- ▶ **Primary:** Settling of solids, floating of oils & grease. Solids and oils removed.*
- ▶ **Secondary:** Separation and removal of smaller dissolved and suspended particles.*
- ▶ **Tertiary** (or Next Level of Treatment): Further level of filtration to remove even more pollution.*

*(Digesters used to process all removed solids, oils, and suspended particles.)



Next Level of Treatment



- ▶ Next Level of Treatment would add more pollution reduction for the River
- ▶ Phosphorus, PCBs, metals
- ▶ Optimize sizing of NLT
- ▶ Consider needs of NLT along with needs for CSO storage




Our proposal

- ▶ Membrane technology sized at 50 million gallons a day capacity.
- ▶ Expand primary and secondary treatment to handle 125 million gallons a day.
- ▶ Include some “bypass” of tertiary (next level) of treatment in intense storms.
- ▶ Build facility so it’s expandable.
- ▶ Why?
 - Net environmental benefit
 - Lower life cycle costs
 - Lower cost per pound of phosphorus removal
- ▶ Other option was sand filters sized at 100 MGD


Options Schematic



Ways to reduce “bypass”


- ▶ Infiltration & Inflow (I/I) reduction
 - ▶ Efficient operation of NLT
 - ▶ Water conservation
 - ▶ Flexible operation of CSO regulators
 - ▶ Connection between streets and stormwater
 - Removal of stormwater from the combined system through the addition of green.
 - Reduce stormwater to plant in incomplete separation areas.
- 

Environmental Benefit


- ▶ Greater phosphorus and CBOD removal from membranes sized at 50 MGD than sand filter option. (CBOD is linked to dissolved oxygen)
 - ▶ PCB removal is about the same.
 - ▶ Membranes also effective at removing other pollutants, such as metals.
 - ▶ And can get additional environmental benefits from running next level of treatment year round.
- 

Financial comparison


Total Present Worth of Filters and Membranes



Cost of lb of phosphorus removal



What would it look like?





Integration is expanding! >>

Thank you!

