

**CITY OF SPOKANE,
WASHINGTON**

CSO FLOW MONITORING PROJECT

FLOW, FREQUENCY AND DURATION

SEWER MAINTENANCE

**Monthly Report
June 2017**

July 6, 2017
CSOMonthly2017-06.docx

OVERFLOW EVENTS

Table 1 – Flow-Frequency-Duration, provides a summary of the flow volume calculated for the overflow pipes at each site for each event recorded. The flow calculations are based on flow monitor recorded level and velocity measurements.

Table 1 – Flow-Frequency-Duration

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
1	AL Parkway Storage (West)	2	None				
2	NW Blvd @ Kiernan	6	None				
3	Columbia @ Downriver	7	None				
4	Nettleton @ York/Buckeye	10	None				
5	Nora @ Pettet	12	None				
6	Sherwood @ Summit	14	1	Total	16,260	30	Missing data 06/12 13:30 to 06/12 13:25
				06/15	16,260	30	
7	Nettleton @ Ohio	15	None				
8	A @ Linton	16B	None				
9	7th @ Inland Empire	19	None				
10	3500 High Drive	20	None				
11	Main @ Oak	22B	None				
12	Cedar @ Ide	23	1	Total	3,372	30	Missing data 06/14 13:35 to 06/14 13:40
				06/15	3,372	30	
13	Riverside @ Cedar (West)	24A	3	Total	259,365	155	
				06/01	95,057	45	
				06/15	107,269	55	
				06/26	57,039	55	
14	Riverside @ Cedar (East)	24B	1	Total	377	10	Missing data 06/29 09:20 to 06/29 09:25
				06/15	377	10	

¹ Designation as an event means that both a level and velocity reading were recorded concurrently. Not all level and velocity readings that were coincident are included in this report, however. The level and velocity readings that appear to be “background noise” from the electronic equipment are not included in the table.

² The flows presented in this column are calculated from measurements of velocity and depth of flow by electronic devices inserted in the water stream. These measurements are subject to singular and possibly cumulative errors. These errors result from limitations inherent in the measuring devices and from the introduction of a measuring device in to the physical flow stream. Also, error in velocity and depth measurements may be and typically are introduced by the physical conditions of each site. The flow numbers presented in this table are estimates only.

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
15	Cedar @ Main	25	3	Total	25,374	65	
				06/01	1,683	10	
				06/15	18,058	40	
				06/26	5,633	15	
16	Riverside @ Lincoln	26	4	Total	1,532,048	170	
				06/01	343,190	40	
				06/15	905,819	65	
				06/26	279,451	55	
				06/28	3,588	10	
17	Arthur @ 5th	33A	3	Total	5,215	60	
				06/01	2,601	25	
				06/15	2,248	25	
				06/26	366	10	
18	Perry @ 3rd	33B	1	Total	146,527	15	
				06/01	146,527	15	
19	Arthur @ 3rd	33C	2	Total	7,470	50	Missing data 06/15 20:05 to 06/15 20:35
				06/01	5,040	20	
				06/15	2,430	30	
20	Sprague Ave @ Sprague Wy	33-2	None				Missing data 06/30 08:20 to 06/30 08:25
21	Riverside @ Napa/Crestline	34	1	Total	5,172	15	
				06/01	5,172	15	
22	S. Riverton @ Magnolia	38	None				
23	Rebecca @ Upriver	41	1	Total	20,405	60	Flow monitor taken out of service 06/21 10:15; No sewer connection to outfall due to construction
				06/15	20,405	60	
24	Riverton @ Surro	42	None				
25	RPWRF CSO-Related Bypass	N/A	None				Permit Section S13.H
	Monthly Total		21		2,021,585	660	No Dry Weather Overflows No RPWRF CSO-Related Bypasses

Table 2 – Rainfall Summary³

	1004	343	344	Shadle	Hartson	CityHall	Joe_Albi	RkwdVsta	Station8	W_Drive	Nora&Pet	GEG			NWS			SFF
Date	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Snow	Dpth	Rain	Snow	Dpth	Rain
06/01/17	0.02P	0.19	0.24	0.01	0.19	0.07	0.01	0.16	0.13	0.06	0.03	0.03	-	-	0.10	-	-	0.09
06/02/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/03/17	-	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	0.01
06/04/17	-	0.03	0.02	-	0.02	0.01	-	0.02	0.03	0.01	-	T	-	-	0.02	-	-	0.03
06/05/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/06/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/07/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/08/17	0.02	0.11	0.09	0.07	0.12	0.07	0.05	0.10	0.12	0.07	0.07	0.06	-	-	0.03	-	-	0.09
06/09/17	OP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/10/17	-	0.06	-	-	0.08	0.03	0.01	-	0.02	-	0.01	-	-	-	-	-	-	0.11
06/11/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/12/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/13/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/14/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/15/17	0.46	0.21	0.20	0.35	0.25	0.40	0.27	0.45	0.36	0.44	0.59	0.38	-	-	0.22	-	-	0.37
06/16/17	0.01	0.03	0.05	0.01	0.05	0.02	-	0.09	0.04	0.02	0.12	0.03	-	-	0.06	-	-	0.03
06/17/17	OP	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
06/18/17	-	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
06/19/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/20/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/21/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	M	M	M	-
06/22/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/23/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/24/17	OP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/25/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/26/17	0.36	0.15	0.20	0.07	0.10	0.13	0.22	0.20	0.13	0.24	0.08	0.14	-	-	0.18	-	-	0.18
06/27/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/28/17	0.07	0.13	0.10	0.06	0.10	0.10	0.08	0.16	0.07	0.10	0.09	0.07	-	-	0.11	-	-	0.09
06/29/17	-	0.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/30/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/01/17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	0.94	0.92	0.90	0.57	0.91	0.83	0.64	1.18	0.90	0.94	0.99	0.71	0.00		0.72	0.00		1.00

- E - Erroneous data
- M - Missing data
- P - Partial missing data
- T - Trace of rain/snow
- X - Out of Service

Table 3 – Rain Gauges

1004	Airway Heights
343	23 rd & Ray
344	Division & Manito
Shadle	Shadle Water Tower (was 345)
Hartson	Ray & Hartson (was 346)
CityHall	City Hall (was 347)
Joe_Albi	Joe Albi Stadium
RkwdVsta	Rockwood Vista
Station8	Fire Station 8, Rebecca & Mission
W_Drive	West Drive Reservoir
Nora&Pet	Nora & Pettet
GEG	Spokane Airport
NWS	National Weather Service – Spokane
SFF	Spokane Felts Field

³ Some rain gauges are heated. Consequently they will tend to record snow melt immediately as rain. The rain gauges that are not heated will typically register snow melt when it actually melts.