

**CITY OF SPOKANE,
WASHINGTON**

CSO FLOW MONITORING PROJECT

FLOW, FREQUENCY AND DURATION

SEWER MAINTENANCE

**Monthly Report
June 2018**

July 6, 2018
CSOMonthly2018-06.docx

OVERFLOW EVENTS

Table 1 – Flow-Frequency-Duration, provides a summary of the flow volume calculated for the overflow pipes at each site for each event recorded. The flow calculations are based on flow monitor recorded level and velocity measurements.

Table 1 – Flow-Frequency-Duration

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
1	AL Parkway Storage (West)	2	None				
2	NW Blvd @ Kiernan	6	None				Missing data 06/20 08:25 to 06/20 08:30
3	Columbia @ Downriver	7	None				
4	Nettleton @ York/Buckeye	10	None				
5	Nora @ Pettet	12	None				
6	Sherwood @ Summit	14	None				
7	Nettleton @ Ohio	15	None				
8	A @ Linton	16B	None				
9	7th @ Inland Empire	19	None				Missing data 06/06 08:25 to 06/06 08:30
10	3500 High Drive	20	None				
11	Main @ Oak	22B	None				

¹ Designation as an event means that both a level and velocity reading were recorded concurrently. Not all level and velocity readings that were coincident are included in this report, however. The level and velocity readings that appear to be “background noise” from the electronic equipment are not included in the table.

² The flows presented in this column are calculated from measurements of velocity and depth of flow by electronic devices inserted in the water stream. These measurements are subject to singular and possibly cumulative errors. These errors result from limitations inherent in the measuring devices and from the introduction of a measuring device in to the physical flow stream. Also, error in velocity and depth measurements may be and typically are introduced by the physical conditions of each site. The flow numbers presented in this table are estimates only.

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
12	Cedar @ Ide	23	None				Missing data 06/01 23:00 to 06/01 23:05 Missing data 06/05 12:00 to 06/05 12:05 Missing data 06/09 00:00 to 06/09 00:05 Missing data 06/10 11:30 to 06/10 11:35 Missing data 06/10 12:25 to 06/10 12:30 Missing data 06/10 15:15 to 06/10 15:20 Missing data 06/10 15:25 to 06/10 15:30 Missing data 06/10 17:45 to 06/10 17:50 Missing data 06/10 18:05 to 06/10 18:10 Missing data 06/10 23:10 to 06/10 23:15 Missing data 06/11 01:40 to 06/11 01:45 Missing data 06/11 02:10 to 06/11 02:15 Missing data 06/11 02:20 to 06/11 02:30 Missing data 06/11 02:35 to 06/11 02:40 Missing data due to construction
13	Riverside @ Cedar (West)	24A	1	Total	595,270	165	
				06/21	595,270	165	
14	Riverside @ Cedar (East)	24B	None				Missing data 06/14 12:25 to 06/14 12:30
15	Cedar @ Main	25	1	Total	43,349	40	
				06/21	43,349	40	
16	Riverside @ Lincoln	26	2	Total	3,201,546	310	
				06/09	42,474	90	
				06/21	3,159,072	220	Volume estimated due to vault surcharge
18	Perry @ 3rd	33B	1	Total	164,382	25	Missing data 06/15 07:35 to 06/15 08:35
				06/21	164,382	25	
19	Arthur @ 3rd	33C	1	Total	10,198	25	
				06/21	10,198	25	
20	Sprague Ave @ Sprague Wy	33-2	None				
21	Riverside @ Napa/Crestline	34	1	Total	382	15	Missing data 06/15 07:50 to 06/15 07:55
				06/21	382	15	
22	S. Riverton @ Magnolia	38	None				
23	Rebecca @ Upriver	41	None				
24	Riverton @ Surro	42	None				
25	RPWRF CSO-Related Bypass	N/A	None				Permit Section S13.H
	Monthly Total		7		4,015,126	580	No Dry Weather Overflows No RPWRF CSO-Related Bypasses

Table 2 – Rainfall Summary³

	343	344	Shadle	Hartson	CityHall	Joe_Albi	RkwdVsta	Station8	W_Drive	Nora&Pet	GEG			NWS			SFF
Date	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Snow	Dpth	Rain	Snow	Dpth	Rain
06/01/18	0.03	0.03	-	0.01	-	0.01	0.01	0.01	0.01	-	T	-	-	0.01	-	-	0.02
06/02/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/03/18	-	-	-	-	-	-	-	-	-	-	T	-	-	0.02	-	-	T
06/04/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/05/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/06/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/07/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/08/18	0.08	0.01	0.06	0.09	0.01	0.02	0.05	0.06	0.02	0.01	0.05	-	-	T	-	-	0.04
06/09/18	0.34	0.29	0.23	0.28	0.20	0.21	0.36	0.32	0.23	0.20	0.22	-	-	0.27	-	-	0.33
06/10/18	-	-	0.01	-	-	0.04	-	-	0.01	0.01	T	-	-	0.04	-	-	T
06/11/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/12/18	-	-	-	-	-	-	0.02	-	-	-	-	-	-	-	-	-	-
06/13/18	0.01	0.01	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
06/14/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/15/18	-	-	-	-	-	-	-	-	-	-	0.01	-	-	T	-	-	-
06/16/18	0.05	0.04	0.01	0.09	0.02	0.01	0.06	0.05	0.02	-	0.01	-	-	0.02	-	-	0.08
06/17/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/18/18	0.02	0.01	-	0.01	-	-	0.01	0.02	0.01	0.01	0.01	-	-	0.02	-	-	0.02
06/19/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/20/18	-	-	-	-	-	-	-	-	-	-	T	-	-	-	-	-	-
06/21/18	0.33	0.40	0.25	0.28	0.35	0.17	0.72	0.16	0.60	0.21	0.25	-	-	0.73	-	-	0.35
06/22/18	-	-	-	-	-	0.02	-	-	-	-	-	-	-	T	-	-	T
06/23/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/24/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/25/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/26/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/27/18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06/28/18	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-
06/29/18	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
06/30/18	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
Total	0.86	0.79	0.56	0.76	0.58	0.48	1.23E	0.62	0.90	0.44	0.55	0.00	-	1.11	0.00	-	0.84

- E - Erroneous data
- M - Missing data
- P - Partial missing data
- T - Trace of rain/snow
- X - Out of Service

Table 3 – Rain Gauges

343	23 rd & Ray
344	Division & Manito
Shadle	Shadle Water Tower (was 345)
Hartson	Ray & Hartson (was 346)
CityHall	City Hall (was 347)
Joe_Albi	Joe Albi Stadium
RkwdVsta	Rockwood Vista
Station8	Fire Station 8, Rebecca & Mission
W_Drive	West Drive Reservoir
Nora&Pet	Nora & Pettet
GEG	Spokane Airport
NWS	National Weather Service – Spokane
SFF	Spokane Felts Field

³ Some rain gauges are heated. Consequently they will tend to record snow melt immediately as rain. The rain gauges that are not heated will typically register snow melt when it actually melts.