

CITY OF SPOKANE, WASHINGTON

CSO FLOW MONITORING PROJECT

FLOW, FREQUENCY AND DURATION

SEWER MAINTENANCE

**Monthly Report
March 2018**

April 12, 2018
CSOMonthly2018-03.docx

OVERFLOW EVENTS

Table 1 – Flow-Frequency-Duration, provides a summary of the flow volume calculated for the overflow pipes at each site for each event recorded. The flow calculations are based on flow monitor recorded level and velocity measurements.

Table 1 – Flow-Frequency-Duration

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
1	AL Parkway Storage (West)	2	None				
2	NW Blvd @ Kiernan	6	None				
3	Columbia @ Downriver	7	None				
4	Nettleton @ York/Buckeye	10	None				
5	Nora @ Pettet	12	None				
6	Sherwood @ Summit	14	None				
7	Nettleton @ Ohio	15	None				
8	A @ Linton	16B	None				Missing data 03/14 12:55 to 03/14 13:20 Missing data 03/25 16:00 to 03/25 16:05 Missing data 03/26 04:00 to 03/26 04:05 Missing data 03/26 12:00 to 03/26 12:05 Missing data 03/26 16:00 to 03/26 16:05 Missing data 03/26 20:00 to 03/26 20:05 Missing data 03/27 04:00 to 03/27 04:05 Missing data 03/27 08:00 to 03/27 08:05 Missing data 03/27 12:00 to 03/27 12:05 Missing data 03/27 20:00 to 03/27 20:05
9	7th @ Inland Empire	19	None				
10	3500 High Drive	20	None				
11	Main @ Oak	22B	None				Missing data 03/08 13:25 to 03/08 13:30 Missing data 03/08 13:50 to 03/08 13:55 Missing data 03/22 12:10 to 03/22 12:15
12	Cedar @ Ide	23	None				Missing data 03/26 11:05 to 03/26 12:00 due to construction Missing data 03/28 08:10 to 03/28 09:15 due to construction Missing data 03/30 08:00 to 03/30 08:05

¹ Designation as an event means that both a level and velocity reading were recorded concurrently. Not all level and velocity readings that were coincident are included in this report, however. The level and velocity readings that appear to be “background noise” from the electronic equipment are not included in the table.

² The flows presented in this column are calculated from measurements of velocity and depth of flow by electronic devices inserted in the water stream. These measurements are subject to singular and possibly cumulative errors. These errors result from limitations inherent in the measuring devices and from the introduction of a measuring device in to the physical flow stream. Also, error in velocity and depth measurements may be and typically are introduced by the physical conditions of each site. The flow numbers presented in this table are estimates only.

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
13	Riverside @ Cedar (W est)	24A	1	Total	267	20	Missing data 03/14 12:05 to 03/14 12:10 Missing data 03/14 12:15 to 03/14 12:20
				03/14	267	20	
14	Riverside @ Cedar (East)	24B	None				
15	Cedar @ Main	25	None				
16	Riverside @ Lincoln	26	4	Total	82,181	145	
				03/01	7,263	20	
				03/14	11,989	30	
				03/17	2,882	20	
				03/22	60,047	75	
17	Arthur @ 5th	33A	None				Outfall plugged as of 03/28; no further data. 33A will not appear on future reports. 33A now regulated downstream at 33B
18	Perry @ 3rd	33B	None				
19	Arthur @ 3rd	33C	None				
20	Sprague Ave @ Sprague Wy	33-2	None				Missing data 03/19 09:25 to 03/19 09:30
21	Riverside @ Napa/Crestline	34	None				Missing data 03/09 12:10 to 03/09 12:15 Missing data 03/19 08:25 to 03/19 08:30
22	S. Riverton @ Magnolia	38	None				
23	Rebecca @ Upriver	41	None				
24	Riverton @ Surro	42	None				
25	RPWRF CSO-Related Bypass	N/A	None				Permit Section S13.H
	Monthly Total		5		82,448	165	No Dry Weather Overflows No RPWRF CSO-Related Bypasses

Table 2 – Rainfall Summary³

	1004	343	344	Shadle	Hartson	City Hall	Joe Albi	RkwdVsta	Station8	W Drive	Nora&Pet	GEG			NWS			SFF
Date	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Snow	Dpth	Rain	Snow	Dpth	Rain
03/01/18	X	0.11	0.12	0.18	0.05	0.16	0.22	0.15	0.09	0.17	0.20	0.18	0.90	1	0.23	0.70	3	0.09
03/02/18	X	0.17	0.10	0.06	0.09	0.09	0.11	0.09	0.12	0.10	0.09	0.10	1.30	1	0.13	1.50	3	0.10
03/03/18	X	-	-	0.01	-	-	-	-	-	-	-	-	-	2	-	-	4	-
03/04/18	X	-	-	-	-	-	-	-	-	-	-	T	T	1	T	T	4	T
03/05/18	X	-	-	-	-	-	-	-	-	-	-	T	T	1	-	-	4	-
03/06/18	X	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	3	-
03/07/18	X	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	3	-
03/08/18	X	0.22	0.16	0.17	0.19	0.15	0.16	0.24	0.17	0.16	0.16	0.16	-	-	0.14	-	1	0.17
03/09/18	X	-	-	-	-	-	-	-	-	-	-	T	T	-	T	-	T	-
03/10/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/11/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/12/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/13/18	X	-	-	-	-	-	-	-	-	-	-	0.01	-	-	T	-	-	T
03/14/18	X	0.27	0.24	0.20	0.19	0.18	0.18	0.32	0.23	0.23	0.19	0.19	-	-	0.19	-	-	0.23
03/15/18	X	-	-	0.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/16/18	X	0.01	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	T
03/17/18	X	0.21	0.19	0.13	0.11	0.16	0.13	0.24	0.15	0.14	0.16	0.16	-	-	0.08	-	-	0.13
03/18/18	X	0.04	0.07	0.01	0.02	-	-	-	-	0.02	-	0.01	-	-	M	M	M	0.01
03/19/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/20/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/21/18	X	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
03/22/18	X	0.28	0.23	0.21	0.25	0.22	0.20	0.30	0.26	0.25	0.24	0.22	-	-	0.20	-	-	0.23
03/23/18	X	0.02	-	0.01	-	0.01	-	-	-	0.01	0.01	T	T	-	T	T	-	0.01
03/24/18	X	0.30	0.27	0.24	0.23	0.23	0.29	0.36	0.29	0.26	0.25	0.26	2.70	1	0.28	2.80	-	0.25
03/25/18	X	-	-	-	-	-	-	-	-	-	-	0.01	-	-	-	-	-	-
03/26/18	X	0.01	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	T
03/27/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/28/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/29/18	X	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	-
03/30/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03/31/18	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	0X	1.64	1.38	1.23	1.13	1.20	1.29	1.70	1.31	1.34	1.30	1.30	4.90		1.25	5.00		1.22

- E - Erroneous data
- M - Missing data
- P - Partial missing data
- T - Trace of rain/snow
- X - Out of Service

Table 3 – Rain Gauges

1004	Airway Heights
343	23 rd & Ray
344	Div ision & Manito
Shadle	Shadle Water Tower (was 345)
Hartson	Ray & Hartson (was 346)
City Hall	City Hall (was 347)
Joe Albi	Joe Albi Stadium
RkwdVsta	Rockwood Vista
Station8	Fire Station 8, Rebecca & Mission
W Drive	West Drive Reservoir
Nora&Pet	Nora & Pettet
GEG	Spokane Airport
NWS	National Weather Service – Spokane
SFF	Spokane Felts Field

³ Some rain gauges are heated. Consequently they will tend to record snow melt immediately as rain. The rain gauges that are not heated will typically register snow melt when it actually melts.