

**CITY OF SPOKANE,
WASHINGTON**

CSO FLOW MONITORING PROJECT

FLOW, FREQUENCY AND DURATION

SEWER MAINTENANCE

**Monthly Report
July 2019**

August 7, 2019
CSOMonthly2019-07.docx

OVERFLOW EVENTS

Table 1 – Flow-Frequency-Duration, provides a summary of the flow volume calculated for the overflow pipes at each site for each event recorded. The flow calculations are based on flow monitor recorded level and velocity measurements.

Table 1 – Flow-Frequency-Duration

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
1	AL Parkway Storage (West)	2	None				
2	NW Blvd @ Kiernan	6	None				
3	Columbia @ Downriver	7	None				
4	Nettleton @ York/Buckeye	10	None				
5	Nora @ Pettet	12	None				
6	Sherwood @ Summit	14	None				Missing data 07/08 08:55 to 07/08 09:00 Missing data 07/12 08:55 to 07/12 09:05 Missing data 07/19 08:30 to 07/19 08:35 Missing data 07/19 09:15 to 07/19 09:20 Missing data 07/22 12:50 to 07/22 13:05 Missing data 07/22 13:40 to 07/22 13:45
7	Nettleton @ Ohio	15	None				
8	A @ Linton	16	None				Missing data 07/16 13:25 to 07/16 13:30
9	7th @ Inland Empire	19	None				
11	Main @ Oak	22B	None				Missing data 07/15 08:20 to 07/15 08:25
12	Cedar @ Summit	23-1	None				Missing data 07/02 07:50 to 07/02 07:55 Missing data 07/02 08:10 to 07/02 09:10
15	1st @ Adams	24-1	None				

¹ Designation as an event means that both a level and velocity reading were recorded concurrently. Not all level and velocity readings that were coincident are included in this report, however. The level and velocity readings that appear to be “background noise” from the electronic equipment are not included in the table.

² The flows presented in this column are calculated from measurements of velocity and depth of flow by electronic devices inserted in the water stream. These measurements are subject to singular and possibly cumulative errors. These errors result from limitations inherent in the measuring devices and from the introduction of a measuring device in to the physical flow stream. Also, error in velocity and depth measurements may be and typically are introduced by the physical conditions of each site. The flow numbers presented in this table are estimates only.

Line No.	Regulator Location	CSO No.	Freq.	Date of event ¹	Estimated Total Flow (Gallons) ²	Event Duration (Min. of Overflow)	Comments
16	Cedar @ Main	25	None				Missing data 07/19 12:55 to 07/19 13:00 Missing data 07/29 09:50 to 07/29 09:55
17	Riverside @ Lincoln	26	2	Total	612,517	120	Missing data 07/17 07:45 to 07/17 08:15 Missing data 07/25 13:10 to 07/25 13:15 Missing data 07/29 10:10 to 07/29 10:15
				07/16	501,798	70	
				07/23	110,719	50	
19	Arthur @ 3rd	33C	2	Total	2,429	70	Missing data 07/02 18:00 to 07/02 18:05
				07/16	1,837	55	
				07/23	592	15	
20	Liberty Park (west end)	33-1	None				
21	Sprague Ave @ Sprague Wy	33-2	None				
22	Riverside @ Napa/Crestline	34	1	Total	36,235	45	Missing data 07/12 09:25 to 07/12 09:30 Missing data 07/25 08:40 to 07/25 08:45
				07/16	36,235	45	
23	S. Riverton @ Magnolia	38-1	None				
24	Rebecca @ Upriver	41	None				
25	Riverton @ Surro	42	None				
26	RPWRF CSO-Related Bypass	N/A	None				Permit Section S13.H
	Monthly Total		5		651,181	235	No Dry Weather Overflows No RPWRF CSO-Related Bypasses

Table 2 – Rainfall Summary³

	343	344	Shadle	Hartson	CityHall	Joe_Albi	RkwdVsta	Station8	W_Drive	Nora&Pet	Lincoln	Northeast	Crest&Hoff	GEG			NWS			SFF
Date	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Rain	Snow	Dpth	Rain	Snow	Dpth	Rain
07/01/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/02/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	-
07/03/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-	-	-	-
07/04/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/05/19	-	-	-	-	-	0.01	-	-	0.01	-	-	-	-	T	-	-	0.07	-	-	-
07/06/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-
07/07/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-	-	-	-
07/08/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/09/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-	-	-	-
07/10/19	-	-	0.01	-	-	-	-	-	-	-	-	-	-	T	-	-	0.02	-	-	T
07/11/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	-	-	-	-
07/12/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/13/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	0.01	-	-	-
07/14/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/15/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	0.02	-	-	T
07/16/19	0.47	0.30	0.08	0.47	0.19	0.10	0.78	0.18	0.28	0.29	0.15	0.13	0.12	0.29	-	-	0.07	-	-	0.15
07/17/19	0.02	0.01	-	0.01	-	-	0.02	0.01	0.01	-	-	-	-	T	-	-	0.01	-	-	T
07/18/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/19/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/20/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/21/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/22/19	-	-	-	-	-	-	-	-	-	-	-	-	-	T	-	-	T	-	-	-
07/23/19	0.10	0.13	0.11	0.14	0.09	0.15	0.13	0.15	0.15	0.14	0.08	0.08	0.09	0.12	-	-	0.13	-	-	0.11
07/24/19	0.17	0.13	0.13	0.15	0.18	0.14	0.21	0.17	0.14	0.14	0.18	0.16	0.12	0.11	-	-	0.09	-	-	0.18
07/25/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/26/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/27/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/28/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/29/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/30/19	-	-	-	-	0.04	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07/31/19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	0.76	0.57	0.33	0.77	0.50	0.40	1.14E	0.51	0.59	0.57	0.41	0.37	0.33	0.52	0.00		0.42	0.00		0.44

E – Erroneous data

M – Missing Data

P – Partial Missing data

T – Trace of rain/snow

X – Out of Service

³ Some rain gauges are heated. Consequently, they will tend to record snow melt immediately as rain. The rain gauges that are not heated will typically register snow melt when it actually melts.

Table 3 – Rain Gauges

343	23 rd & Ray
344	Division & Manito
Shadle	Shadle Water Tower (was 345)
Hartson	Ray & Hartson (was 346)
CityHall	City Hall (was 347)
Joe Albi	Joe Albi Stadium
RkwdVsta	Rockwood Vista
Station8	Fire Station 8, Rebecca & Mission
W Drive	West Drive Reservoir
Nora&Pet	Nora & Pettet
Lincoln	Lincoln Rd Lift Station
Northeast	Northeast Lift Station
Crest&Hoff	Crestline & Hoffman
GEG	Spokane Airport
NWS	National Weather Service – Spokane
SFF	Spokane Felts Field