

# **CITY OF SPOKANE, WASHINGTON**

## **CSO FLOW MONITORING PROJECT**

---

### **FLOW, FREQUENCY AND DURATION**

---

#### **SEWER MAINTENANCE**

**Monthly Report  
March 2025**

**April 9, 2025**  
*CSOMonthly2025-03.docx*

## OVERFLOW EVENTS

Table 1 – Flow-Frequency-Duration, provides a summary of the flow volume calculated for the overflow pipes at each site for each event recorded. The flow calculations are based on flow monitor recorded level and velocity measurements.

**Table 1 – Flow-Frequency-Duration**

| Line No. | Regulator Location        | CSO No. | Freq. | Date of event <sup>1</sup> | Estimated Total Flow (Gallons) <sup>2</sup> | Event Duration (Min. of Overflow) | Comments                                                                                                                         |
|----------|---------------------------|---------|-------|----------------------------|---------------------------------------------|-----------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| 1        | AL Parkway Storage (West) | 2       | None  |                            |                                             |                                   |                                                                                                                                  |
| 2        | NW Blvd @ Kiernan         | 6       | None  |                            |                                             |                                   |                                                                                                                                  |
| 3        | Columbia @ Downriver      | 7       | None  |                            |                                             |                                   |                                                                                                                                  |
| 4        | Cochran @ York            | 10      | None  |                            |                                             |                                   |                                                                                                                                  |
| 5        | Pettet Dr & Mansfield     | 12      | None  |                            |                                             |                                   |                                                                                                                                  |
| 6        | Sherwood @ Summit         | 14      | None  |                            |                                             |                                   |                                                                                                                                  |
| 7        | Nettleton @ Ohio          | 15      | None  |                            |                                             |                                   |                                                                                                                                  |
| 8        | Clarke @ Riverside        | 16      | None  |                            |                                             |                                   |                                                                                                                                  |
| 9        | 7th @ Inland Empire       | 19      | None  |                            |                                             |                                   | Missing data 3/12 8:50 to 3/12 8:55                                                                                              |
| 10       | Cedar St @ Summit         | 23-1    | None  |                            |                                             |                                   | Missing data 3/4 13:25 to 3/4 13:30<br>Missing data 3/5 9:30 to 3/6 6:35<br>Missing data 3/6/25 7:50<br>Missing data 3/6/25 8:40 |
| 11       | Sprague @ Adams           | 24-1    | None  |                            |                                             |                                   |                                                                                                                                  |
| 12       | Cedar @ Main              | 25      | None  |                            |                                             |                                   |                                                                                                                                  |
| 13       | Lincoln @ Spokane Falls   | 26      | None  |                            |                                             |                                   | Missing data 3/21 7:35 to 3/21 7:40                                                                                              |
| 14       | Liberty Park (west end)   | 33-1    | None  |                            |                                             |                                   |                                                                                                                                  |

<sup>1</sup> Designation as an event means that both a level and velocity reading were recorded concurrently. Not all level and velocity readings that were coincident are included in this report, however. The level and velocity readings that appear to be “background noise” from the electronic equipment are not included in the table.

<sup>2</sup> The flows presented in this column are calculated from measurements of velocity and depth of flow by electronic devices inserted in the water stream. These measurements are subject to singular and possibly cumulative errors. These errors result from limitations inherent in the measuring devices and from the introduction of a measuring device into the physical flow stream. Also, error in velocity and depth measurements may be and typically are introduced by the physical conditions of each site. The flow numbers presented in this table are estimates only.

March 2025

|    |                                |      |      |  |   |   |                                                           |
|----|--------------------------------|------|------|--|---|---|-----------------------------------------------------------|
| 15 | Sprague Ave west of Sprague Wy | 33-2 | None |  |   |   |                                                           |
| 16 | Riverside @ Crestline          | 34   | None |  |   |   |                                                           |
| 17 | S. Riverton @ Magnolia         | 38-1 | None |  |   |   |                                                           |
| 18 | Rebecca @ Upriver              | 41   | None |  |   |   | Missing data 3/31 7:15                                    |
| 19 | Surro west of Waterworks       | 42   | None |  |   |   |                                                           |
| 20 | RPWRF CSO-Related Bypass       | N/A  | None |  |   |   | Permit Section S13.H                                      |
|    |                                |      |      |  |   |   |                                                           |
|    | Monthly Total                  |      | 0    |  | 0 | 0 | No Dry Weather Overflows<br>No RPWRF CSO-Related Bypasses |

Table 2 – Rainfall Summary<sup>3</sup>

|          | 343  | 344  | Shadle | Hartson | CityHall | RkwdVsta | Station8 | W_Drive | Nora&Pet | Lincoln | Northeast | Crest&Hoff | Flett | GEG  |      |       | NWS  |      |       | SFF  |
|----------|------|------|--------|---------|----------|----------|----------|---------|----------|---------|-----------|------------|-------|------|------|-------|------|------|-------|------|
| Date     | Rain | Rain | Rain   | Rain    | Rain     | Rain     | Rain     | Rain    | Rain     | Rain    | Rain      | Rain       | Rain  | Rain | Snow | Depth | Rain | Snow | Depth | Rain |
| 03/01/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/02/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/03/25 | -    | -    | 0.05   | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | T    | -    | -     | -    | -    | -     | T    |
| 03/04/25 | 0.02 | 0.04 | 0.02   | 0.03    | 0.02     | 0.02     | 0.03     | 0.03    | 0.03     | 0.02    | 0.02      | 0.02       | -     | 0.01 | -    | -     | 0.01 | -    | -     | 0.01 |
| 03/05/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | 0.01  | -    | -    | -     | -    | -    | -     | -    |
| 03/06/25 | 0.01 | -    | 0.01   | -       | -        | -        | -        | -       | -        | -       | 0.01      | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/07/25 | -    | -    | 0.07   | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/08/25 | -    | 1.19 | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/09/25 | -    | -    | 0.01   | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/10/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | T    | T    | -     | -    |
| 03/11/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | T    | T    | -     | 0.01 | T    | -     | T    |
| 03/12/25 | 0.41 | 0.01 | 0.51   | 0.32    | 0.44     | 0.46     | 0.29     | 0.49    | 0.49     | 0.47    | 0.41      | 0.49       | 0.48  | 0.53 | -    | -     | 0.58 | -    | -     | 0.53 |
| 03/13/25 | 0.19 | 0.06 | 0.15   | 0.17    | 0.13     | 0.16     | 0.16     | 0.17    | 0.16     | 0.14    | 0.09      | 0.11       | 0.10  | 0.11 | T    | -     | 0.11 | -    | -     | 0.11 |
| 03/14/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | T    | -    | -     | T    | T    | -     | T    |
| 03/15/25 | 0.28 | 0.15 | 0.16   | 0.17    | 0.19     | 0.24     | 0.12     | 0.21    | 0.20     | 0.40    | 0.17      | 0.18       | 0.23  | 0.17 | 0.40 | T     | 0.24 | 1.70 | -     | 0.17 |
| 03/16/25 | 0.13 | 0.01 | 0.07   | 0.05    | 0.08     | 0.11     | 0.03     | 0.12    | 0.10     | 0.09    | 0.08      | 0.08       | 0.09  | 0.10 | T    | T     | 0.11 | T    | -     | 0.10 |
| 03/17/25 | -    | -    | 0.08   | -       | -        | -        | -        | -       | -        | 0.02    | -         | -          | -     | T    | -    | -     | T    | T    | -     | T    |
| 03/18/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | T    | T    | -     | -    | -    | -     | T    |
| 03/19/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | T    | -    | -     | -    | -    | -     | T    |
| 03/20/25 | 0.08 | 0.02 | 0.03   | 0.04    | 0.04     | 0.04     | -        | 0.07    | 0.05     | 0.08    | 0.05      | 0.05       | 0.04  | 0.04 | -    | -     | 0.05 | -    | -     | 0.04 |
| 03/21/25 | 0.30 | 0.03 | 0.31   | 0.27    | 0.24     | 0.26     | 0.33     | 0.27    | 0.28     | 0.41    | 0.38      | 0.42       | 0.31  | 0.19 | -    | -     | 0.24 | -    | -     | 0.19 |
| 03/22/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | 0.01    | 0.01      | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/23/25 | 0.20 | 0.01 | 0.15   | 0.17    | 0.17     | 0.21     | 0.05     | 0.19    | 0.16     | 0.26    | 0.19      | 0.14       | 0.16  | 0.15 | -    | -     | 0.19 | -    | -     | 0.15 |
| 03/24/25 | 0.03 | 0.25 | -      | 0.02    | 0.01     | 0.02     | 0.02     | 0.04    | 0.03     | 0.02    | 0.02      | 0.02       | 0.01  | 0.02 | -    | -     | T    | -    | -     | 0.02 |
| 03/25/25 | -    | 0.06 | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/26/25 | -    | -    | 0.01   | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | 0.01 | -    | -     | -    |
| 03/27/25 | 0.01 | 0.01 | -      | -       | -        | -        | -        | -       | -        | 0.01    | 0.01      | -          | -     | T    | -    | -     | 0.04 | -    | -     | T    |
| 03/28/25 | 0.15 | 0.01 | 0.08   | 0.12    | 0.07     | 0.12     | 0.10     | 0.12    | 0.09     | 0.11    | 0.10      | 0.11       | 0.09  | 0.11 | -    | -     | -    | -    | -     | 0.11 |
| 03/29/25 | -    | -    | -      | -       | -        | -        | -        | -       | -        | -       | -         | -          | -     | -    | -    | -     | -    | -    | -     | -    |
| 03/30/25 | -    | 1.52 | -      | -       | -        | 0.01     | -        | -       | -        | 0.02    | 0.02      | 0.01       | -     | 0.01 | -    | -     | T    | -    | -     | 0.01 |
| 03/31/25 | 0.06 | -    | 0.15   | 0.04    | 0.05     | 0.07     | 0.04     | 0.16    | 0.32     | 0.24    | 0.08      | 0.13       | 0.09  | 0.12 | T    | -     | 0.08 | -    | -     | 0.12 |
| Total    | 1.87 | 3.37 | 1.86   | 1.40    | 1.44     | 1.72     | 1.17     | 1.87    | 1.91     | 2.30    | 1.64      | 1.76       | 1.61  | 1.56 | 0.40 |       | 1.67 | 1.70 |       | 1.56 |

E – Erroneous Data (Over/Under Count)

M – Missing Data (Whole Day)

P – Partial Missing Data (Less Than 1 Day)

T – Trace of Rain/Snow

<sup>3</sup> Some rain gauges are heated. Consequently, they will tend to record snow melt immediately as rain. The rain gauges that are not heated will typically register snow melt when it melts.

Table 3 – Rain Gauges

|            |                                                 |
|------------|-------------------------------------------------|
| 343        | 23 <sup>rd</sup> & Ray                          |
| 344        | Division & Manito                               |
| Shadle     | Shadle Water Tower (was 345)                    |
| Hartson    | Ray & Hartson (was 346)                         |
| CityHall   | City Hall (was 347)                             |
| RkwdVsta   | Rockwood Vista                                  |
| Station8   | Fire Station 8, Rebecca & Mission               |
| W_Drive    | West Drive Reservoir                            |
| Nora&Pet   | Nora & Pettet                                   |
| Lincoln    | Lincoln Rd Lift Station                         |
| Northeast  | Northeast Lift Station                          |
| Crest&Hoff | Crestline & Hoffman                             |
| Flett      | Flett Middle School (Near old Joe Albi monitor) |
| GEG        | Spokane Airport                                 |
| NWS        | National Weather Service – Spokane              |
| SFF        | Spokane Felts Field                             |